



Prosper Fire Department

1500 E. First Street, P.O. Box 307, Prosper, Texas 75078
(972) 347-2424 Central Station (972) 347-3010 Facsimile

5/18/2016

RE: Fire Pits

Wood burning fire pits

- 10' clearance to combustibles.
- Maximum burn bowl (the interior part of the fire pit where wood is placed) diameter of 36" and height of 24".

Non-wood burning fire pit

- (a "fire feature" that has a gas burner and lava rocks or glass, the outdoor equivalent of the of the indoor non-wood burning fireplace with gas logs): per the manufacturer's installation instructions. In the absence of manufacturer's installation instructions, the regulations will be the same as wood burning fire pits.

Sincerely,

Bryan Ausenbaugh, Fire Marshal
Prosper Fire Dept.

Bryan.ausenbaugh@prosperfire.com