



Prosper Fire Department

1500 E. First Street, P.O. Box 307, Prosper, Texas 75078
(972) 346-9469 Central Station (972) 347-3010 Facsimile

LIMITED ACCESS GATE REQUIREMENTS

1. **Must submit two sets of plans (scaled drawings) for review, BEFORE THE WORK BEGINS. The following information should be clearly indicated on the plans:**
 - Name and address of complex must be on plans.
 - Existing and proposed fencing and existing limited access gates including driveway gates and pedestrian gates.
 - Proposed location of entrance and exit gates, pedestrian gates, fire department hinged fence panel for fire hydrant access and types of equipment being installed should be clearly indicated on the plans. (i.e. types of driveway gates : slide, double-slide, swing, double swing, or vertical access gates: types of pedestrian gates: Knox key switch, fire department window with Knox padlock, or fire department access fence panels with Knox padlock.)
 - Number and location of Knox padlocks, Knox key switches and Radio receivers requested.

We will not review your plans unless the above items are properly marked on the plans. They will be returned for corrections and must be re-submitted. NO EXCEPTIONS MADE.

2. **Submit or mail to:**
Prosper Fire Department
P.O. Box 307
1500 East First St
Prosper, Tx 75078
3. **Fire department equipment will be used to assist in design of the gates as well as the turning radius required to enter and exit the property.**
4. **Plans will be reviewed and stamped by PFD once compliance is confirmed. One copy of the plans will be returned to the contractor with a completed Knox order form.**