



Prosper Fire Department

1500 E. First Street, P.O. Box 307, Prosper, Texas 75078
(972) 347-2424 Central Station (972) 347-3010 Facsimile

The following items are the top ten most common problems encountered during annual inspections:

- 1.) Fire extinguishers out of service or missing
- 2.) Exit lights not working
- 3.) Extension cords used as permanent wiring
- 4.) Storage too close to sprinkler heads or ceiling
- 5.) Combustible materials too close to hot water heater or heating unit
- 6.) Loose electrical wiring and gaps where breakers are missing in the breaker box
- 7.) Untested sprinklers, alarm, and hood systems
- 8.) Locked or blocked exits
- 9.) Address missing
- 10.) Fire lanes need to be restriped

Bryan Ausenbaugh, Fire Marshal
Prosper Fire Dept.
bryan.ausenbaugh@prosperfire.com