



Annual System Maintenance Period Daily Disinfectant Residuals

Thursday, March 6, 2025	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
Custer Pump Station	1.21	0.92
920 Jessica Ln	2.14	0.00
4460 Honeyvine Ln	2.16	0.00
5681 Crestwood Dr	1.18	0.00
Craig Street Water Tower	2.18	0.00
Prosper Trail Water Tower	2.14	0.00
Fishtrap Water Tower	2.29	0.00
8844 Prestonview Dr	2.35	0.00
Main St & First St	1.27	0.00
Technology Way	1.64	0.00
Gateway Dr	1.22	0.13
HEB (Frontier & DNT)	1.80	0.00
2611 Townlake Dr	1.06	0.96
4710 Zelder St	1.12	0.00
Costco	2.04	0.00