



Annual System Maintenance Period Daily Disinfectant Residuals

Tuesday, March 18, 2025	Total Chlorine Residual (mg/L)	Free Chlorine Residual (mg/L)
Custer Pump Station	2.85	2.65
920 Jessica Ln	2.34	2.03
4460 Honeyvine Ln	2.26	2.04
5681 Crestwood Dr	1.99	1.73
Craig Street Water Tower	2.44	2.18
Prosper Trail Water Tower	2.50	2.28
Fishtrap Water Tower	2.60	2.30
4210 Wilson Creek Trl	2.94	2.51
Main St & First St	1.80	1.52
Technology Way	1.69	1.35
Safety Way	1.86	1.52
HEB (Frontier & DNT)	1.45	1.13
PISD Stadium	1.93	1.71
4710 Zelder St	2.06	1.62
5700 Glencoe Dr	1.29	1.08