

Saturday, March 5, 2022	Total Chlorine Residual	Free Chlorine Residual
Custer Pump Station	2.82	2.61
920 Jessica Ln	1.72	1.55
4460 Honeyvine Ln	1.10	0.79
5681 Crestwood Dr	1.40	1.13
Craig Street Water Tower	1.79	1.47
Prosper Trail Water Tower	1.90	1.52
Fishtrap Water Tower	1.82	1.40
201 E 6th St	1.70	1.40
Glenbrooke North	0.80	0.23
1100 English Ivy Dr	1.15	0.59
4540 Honeyvine Ln	1.28	0.92
4400 Bristleleaf Ln	2.04	1.60
1050 Waterview Dr	0.42	0.23
Mill Branch & Bunton Branch	0.94	0.38
300 W Broadway St	1.59	1.25
Main & First	0.98	0.67
Redi Mix Entrance	2.30	1.84
DNT & First	2.61	2.13
380 Business Park	0.68	0.39
Kent Dr	1.34	0.91
Overhill	2.38	1.84
Stonehaven	2.31	1.90
Spring Hill	2.22	1.32
Falls View	2.23	1.62