

2017 Annual Water Quality Report

Town of Prosper

PWS ID # 0430009

What is the Quality of My Water?

The Town of Prosper is pleased to share this water quality report with you. It describes to you, the customer, the quality of your drinking water. This report covers January 1, 2017, through December 31, 2017. The Town of Prosper's drinking water supply surpassed the strict regulations of both the State of Texas and the U.S. Environmental Protection Agency (EPA), which requires all water suppliers to prepare reports like this every year.

All of the water for the Town of Prosper is treated water purchased from the North Texas Municipal Water District (NTMWD). NTMWD relies on surface water from Lavon Lake, Lake Texoma, and Jim Chapman Lake (Cooper Lake). Your water is treated through sedimentation, filtration, and disinfection to reduce or remove harmful contaminants that may be present in your drinking water.

A Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality and will be provided to us later this year. The report will describe the susceptibility and types of constituents that may come into contact with your drinking source based on human activities and natural conditions. The information contained in the assessment will allow us to focus our source water protection strategies. For more information on source water assessments and protection efforts on our system, please contact the Public Works Department at (972) 347-9969.

If you have any questions about this report or concerning your water utility, please contact the Town of Prosper at (972) 347-9969 or visit our website at www.prospertx.gov. We want the Town of Prosper residents to be informed about their water utility. You can attend regular Town Council meetings on the 2nd and 4th Tuesday of every month, at the Prosper Municipal Chambers, 108 W. Broadway Street, Prosper, Texas at 6:00 PM.

In the water loss audit submitted to the Texas Water Development Board for 2017, our system lost an estimated 10.98 gallons of water per connection per day. According to the report, our system had a total of 4.51% unaccountable water use for 2017, which is 5.49% under our goal for the year. If you have questions about water losses, please contact the Town of Prosper at (972) 347-9969.

For the latest information on water restrictions and helpful tips on how to conserve water and lower your utility bill, visit our website at www.prospertx.gov/water-conservation.

The U.S. Environmental Protection Agency (EPA) wants you to know:

In order to ensure that the tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health. The sources of our drinking water (both tap water and bottled water) comes from rivers, lakes, streams, ponds, reservoirs, springs, and wells. When water runs over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Contaminants that may be present in source water include:

Inorganic Contaminants—Salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas productions, mining, or farming.

Microbial Contaminants—Viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

Organic Chemical Contaminants—Synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, which may come from gas stations, urban storm runoff, and septic systems.

Pesticides and herbicides—May come from a variety of sources such as, agriculture, urban storm water runoff, and residential uses.

Radioactive Contaminants—Can be naturally occurring or be the result of oil and gas production and mining activities.

Important Health Information

Some may be more vulnerable, than the general population, to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immune compromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additionally, guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

The simple fact is, bacteria and other microorganisms inhabit our world. Some are harmful to us, and some are not. Coliform bacteria are common in the environment but are generally not harmful. The presence of this bacterial form in drinking water is a concern because it indicates that the water may be contaminated with other organisms that can cause disease. Throughout the year, we have tested water samples for coliform bacteria, and in that time, one of the samples came back positive for the bacteria. Federal regulation now requires that public water, that tests positive for coliform bacteria, must be further analyzed for fecal coliform bacteria. Fecal coliform are present only in human and animal waste. Because these bacteria can cause illness, it is unacceptable for fecal coliform to be present in water at any concentration. **Our tests indicate no fecal coliform is present in our water.**

2017 Monitoring Results for the Town of Prosper

Results are from Town of Prosper and NTMWD

Coliform Bacteria						
Max Contaminant Level Goal	Total Coliform Max Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Max Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 Positive Monthly Sample	0	0	0	No	Naturally present in the environment.

Note: Reported monthly tests found no fecal coliform bacteria. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.

Regulated Contaminants

Contaminant	Year	Highest Level Detected	Range Detected	MCLG (MRDLG)	MCL (MRDL)	Units	Violation	Likely Sources of Contaminant
Disinfectants and Disinfection By-products								
Chlorine Residual (Chloramines)	2017	3.9	0.56-3.9	(<4.0)	(4.0)	ppm	No	Disinfectant used to control microbes.
Chlorite	2017	0.072	0.00-0.072	No Goal	(1.0)	ppm	No	Disinfectant.
Total Haloacetic Acids	2017	32.8	14.0-32.8	No Goal	60	ppb	No	By-product of drinking water chlorination.
Total Trihalomethanes	2017	53.5	17.6-53.5	No Goal	80	ppb	No	By-product of drinking water chlorination.
Organic Contaminants								
Atrazine	2017	0.2	0.2-0.2	3	3	ppb	No	Runoff from herbicide used on row crops.
Di (2-ethylhexyl) adipate	2017	ND	0-0	400	400	ppb	No	Discharge from chemical factories.
Simazine	2017	ND	0-0	4	4	ppb	No	Herbicide runoff.
Inorganic Contaminants								
Barium	2017	0.06	0.059-0.06	2	2	ppm	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride	2017	0.38	0.26-0.38	4	4	ppm	No	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate (Measured as Nitrogen)	2017	0.97	0.09-0.97	10	10	ppm	No	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.

Copper and Lead								
Contaminant	Year	MCLG	AL	90th Percentile	Sites over AL	Units	Violation	Likely Source of Contamination
Copper	2015	0	1.3	0.21	0	ppm	No	Erosion of natural deposits; Leaching from wood preservatives; corrosion of household plumbing systems.
Lead	2015	0	15	0.0023	0	ppb	No	Corrosion of household plumbing systems; erosion of natural deposits.
<p>Note: If present, elevated levels of lead can cause serious health problems, especially for pregnant woman and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Prosper is responsible for providing high quality drinking water, but the Town cannot control the variety of materials used in plumbing components. When water has been sitting for several hours, minimize the potential for lead exposure by flushing the tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.</p>								
Unregulated Contaminants								
Contaminant	Year	Highest Level Detected	Range Detected	Units	Likely Source of Contamination			
Disinfection By-products								
Chloroform	2017	14.0	6.01-14.0	ppb	By-product of drinking water disinfection.			
Bromoform	2017	5.49	<1-5.49	ppb	By-product of drinking water disinfection.			
Bromodichloromethane	2017	18.4	5.84-18.4	ppb	By-product of drinking water disinfection.			
Dibromochloromethane	2017	15.6	4.28-15.6	ppb	By-product of drinking water disinfection.			
<p>Note: Chloroform, Bromoform, Bromodichloromethane, and Dibromochloromethane are disinfection by-products. There is no MCL for these chemicals at the entry point to distribution.</p>								
Secondary Constituents								
Chloride	2017	108	14-108	ppm	Abundant naturally occurring element; used in water purification; by-product of oil field activity.			
Iron	2017	0.3	0.00-0.3	ppm	Erosion of natural deposits; iron or steel water delivery equipment or facilities.			
Magnesium	2017	11.6	4.41-11.6	ppm	Abundant naturally occurring element.			
pH	2017	8.52	7.85-8.52	units	Measure of corrosivity of water.			
Sulfate	2017	266	47.1-266	units	Naturally occurring; common industrial by-product; by-product of oil field activity.			
Total Dissolved Solids	2017	562	292-562	ppm	Total dissolved mineral constituents in water.			
Total Hardness as CaCO3	2017	236	124-236	ppm	Natural occurring calcium.			

Definitions:

AL (Action Level)—The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

EPA—Environmental Protection Agency.

MCL (Maximum Contaminant Level)—The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal)—The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level)—The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Disinfectant Level Goal)—The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

ND—Not detectable at testing limits.

NTMWD—North Texas Municipal Water District.

ppb (parts per billion)—One part substance per billion parts water. Micrograms per liter (ug/l).

ppm (parts per million)—One part substance per million parts water. Milligrams per liter (mg/l).

Secondary Constituents—Found in drinking water and can cause taste, color, and odor problems. The taste and odor constituents are regulated by the state of Texas, not the EPA.

These constituents are not causes for health concern.

90th Percentile—90% of samples are equal to or less than the number reported in the chart.

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. (972) 346-2640 para hablar con una persona bilingüe en español.