



PROSPER FIRE RESCUE

FIRE MARSHAL'S OFFICE

PO Box 307
1500 E. First Street
Prosper, Texas 75078
Phone (972) 346-9469 Fax (972) 347-3010
www.prosperfire.com



Concession Tent & Canopy Fire Prevention Guide

Extinguisher Requirements

All cooking vendors are required to have at least one extinguisher



- At least one 5 lb. Class "ABC" rated extinguisher with a minimum of a 2A:40BC rating
- Visible current inspection tag
- Fully Charged (gauge indicates full)
- Located within 30 feet of commercial-type cooking equipment
- Would prefer they be visibly bracket mounted to canopy arm

Does your cooking operation produce grease-laden vapors? (Grills, fryers) If so, in addition to the portable extinguisher listed above your operation requires;



- At least one Class "K" rated, 6-liter portable extinguisher
- Visible current inspection tag
- Fully Charged (gauge indicates full)
- Located within 30 feet of commercial-type cooking equipment

Compressed Gas

LP/Propane cylinders are properly secured and remain secured by one of the following methods unless actively being refilled;



- Nested and secured by one or more restraints
- Secured by one or more restraints to a fixed object.
- Minimum of a 10-foot clearance from any trash or combustible material
- Tanks less than 500 lbs. water weight must have a minimum separation of 10 feet from any canopy and out of the public way. Tanks more than 500 lbs. water weight must have minimum separation of 25 feet from any canopy and out of the public way.

Generator



- Located out of the public way and a minimum separation of 20 feet from the canopy
- A minimum separation of 15 feet from propane tanks
- Extension cord of 12 gauge wire with ground and GFCI connection
- Extinguisher located within 30 feet of the generator

Egress and Emergency Access

- The placement of the concession operation does not interfere with fire lane, fire break, fire hydrant, or exit access of any proximate structures.

All cooking equipment shall be separated from the general public by an approved method. The Fire Marshal's office shall inspect all food vendor sites for fire & life safety compliance.

Please contact us if you have any questions regarding these requirements or any Fire Prevention questions for your event. Our goal is to assist you with fire safety and preparedness through the dissemination of fire prevention information and education.