



# PROSPER FIRE RESCUE

## FIRE MARSHAL'S OFFICE

PO Box 307

1500 E. First Street

Prosper, Texas 75078

Phone (972) 346-9469 Fax (972) 347-3010 [www.prosperfire.com](http://www.prosperfire.com)

This document is provided to assist with questions or concerns regarding plan review, fire & life safety features, and/or what may be required at the final acceptance inspection as prescribed by PFD Ordinance.

Please review all of your approved plans and documents for accuracy. Always refer to your IBC & IFC as well as the Prosper Amendments, Policies & Procedures found on our website @ <http://www.prosperfire.com>

**Bureau Veritas** is the exclusive 3<sup>rd</sup> Party plan review firm for all "New and Remodel Commercial Construction Fire Protection Service" related projects. (All related expenses are the responsibility of the contractor, owner, or designated agent).

### Bureau Veritas

100 E. 15<sup>th</sup> St, Fort Worth, Texas 76102

Phone: 817-335-8111

**Final Fire & Life Safety Inspection (as applicable) – All information can be found in our amendments, the IFC, or our Web page @ <http://www.prosperfire.com>**

- a. Submit your request for inspection to [fire.inspections@prosperfire.com](mailto:fire.inspections@prosperfire.com) (Forms found on our Web page)
- b. All construction approved & stamped drawings on-site at the time of inspection
- c. Building address and/or suite address on front & back doors (where applicable)
- d. Fire lane marking and other fire service features (where required)
- e. Outside Utility(s) equipment signage
- f. Emergency exit door identification and locking requirements (Door lock indicator, door signage, panic hardware, etc.)
- g. Exit and emergency light illumination per approved drawings
- h. Fire barrier/wall marking and integrity (See [Prosper Signage Requirements](#)) on our web page at <http://www.prosperfire.com>
- i. Labeling & door identification signage (electrical, mechanical, sprinkler riser, fire alarm control panel rooms, etc.)
- j. Clearance around electrical panels (i. e. floor striping and signage, etc.) (See [Prosper Signage Requirements](#))
- k. Storage height limitation markings (See [Prosper Signage Requirements](#))
- l. All fire protection sub-contractor final inspection reports, close-out documents & certifications on file with the PFD (sprinkler, fire alarm, hood suppression, HVAC controls, access control, elevators, etc.)
- m. Hand portable fire extinguishers of the proper size, quantity, and location installed with current tags affixed
- n. Knox Box location, installation, and size compliance at the sprinkler riser room, main entrance & elevator lobbies (where applicable)
- o. Knox Box Keys with identification tags (all necessary keys to gain access into the structure & internal spaces, elevator, and fire alarm control units) for all Knox Boxes
- p. Bio-Directional Amplification of emergency radio communications may be required at the owner's expense
- q. Blue Card for a signature to obtain the Certificate to Occupy

1) [For more information, visit our web page listed below, and/or for questions contact one of the numbers listed below.](#)

Web page: [www.prosperfire.com](http://www.prosperfire.com) Email Correspondence: [fire.inspections@prosperfire.com](mailto:fire.inspections@prosperfire.com)

Technical Questions: 972-346-9469

General Questions: 972-347-2424