



PROSPER FIRE RESCUE

FIRE MARSHAL'S OFFICE

PO Box 307
1500 E. First Street
Prosper, Texas 75078
Phone (972) 346-9469 Fax (972) 347-3010 www.prosperfire.com

Daycare Annual Inspection Checklist

This inspection checklist is provided as a courtesy to assist with your Annual Fire & Life Safety Inspection requirements

Facility Name: _____
Address: _____
City, State & Zip: _____
Contact Name: _____

Email Address: _____
Phone Number: _____
Date: _____

P F N/A General Housekeeping Precautions

- Accumulation of combustible waste materials
- Weeds, grass, vines capable of being ignited
- Proper storage of combustible rubbish
- Containers of combustible rubbish in proper locations
- Compliance with open flame, fire & burning
- Vehicle impact protection general
- Fueled equipment (lawn equipment, generators, etc.)
- Storage maintained 18" below sprinkler deflector
- Storage in electrical, boiler, mechanical rooms, etc.

P F N/A Emergency Planning & Fire Service Features

- Fire safety, evacuation & emergency preparedness plans
- Verify documented fire and emergency evacuation drills
- Fire apparatus access roads
- Fire apparatus access markings
- Fire apparatus access obstructions (vehicles parked in fire lane)
- Access to building openings & roofs
- Address visible from street (6" letters)
- Key box access & verification of necessary keys
- Fire protection water supplies
- Fire protection/utility equipment access/identification

P F N/A Electrical Equipment & Wiring Hazards

- Electrical wiring to NFPA 70, current edition
- Proper illumination of elect., boiler, mechanical rooms, etc.
- Working space & clearance of electrical service equip.
- Proper identification & labeling of doors
- Proper use of extension cords
- Unapproved condition (missing covers, switches, outlets, etc)

P F N/A Fire Resistance & Rated Construction

- Penetrations sealed in floors, walls & ceilings (missing tiles)
- Hold open and closer devices (door holders, dampers, etc.)
- Door operations compliant

P F N/A Interior Finish, Decorative Materials & Furnishings

- General Provisions
- Interior wall, ceiling & floor finishes
- Upholstered furniture & mattresses
- Decorative vegetation
- Storage in corridors & lobbies
- Artwork & teaching materials (20% of wall space)

P F N/A Fire Protection

- Fire alarm system maint. in operative condition (current tag)
- Access control drops out upon alarm or power loss
- Offsite monitoring service of systems (current tag)
- Sprinkler system maint. in operative condition (current tag)
- Hood suppression maint. in operative condition (current tag)
- Excessive grease build-up & cleaning records
- Extinguishers maint. in operative condition (current tag)
- Extinguishers unobstructed & unobscured
- Extinguisher hangers, brackets & cabinets
- Access to fire department connections
- Locking FDC connection caps
- Clear space around FDC connections

P F N/A Means of Egress

- Means of egress obstructed (reduced or blocked)
- Emergency lighting operational under battery power
- Door swing direction
- Door opening force
- Door locks & latches
- Access controlled egress doors
- Panic & fire exit hardware maintenance
- Exit Signs visible and operational under battery power

P F N/A Other

- Discontinuing operation of unsafe appliances
- Backflow prevention devices comply with the TCEQ

Comments: _____

Inspector's Name: _____

Responsible Person: _____