

## FLOW TEST INFO

JOB NAME / NUMBER:

WalMart #6300

JOB ADDRESS:

500 Richland Blvd

STATIC:

80

RESIDUAL:

79

PITOT:

70

OUTLET DIAMETER:

2.5

NUMBER OF OUTLETS:

1

COEFFECIENT OF DRAG:

0.9

FLOW:

1403.86323