



Mobile Food Vendor Vehicle

This inspection checklist is provided as a courtesy to assist with your kitchen hood suppression installation requirements

Project Name: _____

Permit # _____

Address: _____

City, State & Zip: _____

Date: _____

Phone Number: _____

Y	N	N/A	Appliances
---	---	-----	------------

- | | | | |
|--------------------------|--------------------------|--------------------------|--|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are the appliances within the perimeter of the hood a minimum of 6 inches? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are deep fat fryers a minimum of 16" away from an open flame or have an 8" steel or tempered glass baffle installed? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are the fuel fire appliances compliant? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are the electrical appliances compliant? |

Y	N	N/A	Hood Suppression System
---	---	-----	-------------------------

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Does the vent hood suppression system have a current certification tag? |
|--------------------------|--------------------------|--------------------------|---|

Y	N	N/A	Compressed Gas Cylinders
---	---	-----	--------------------------

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are cylinders properly stored? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are cylinders protected from physical damage? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are cylinders, fittings, hoses and/or piping free of physical damage? |

Y	N	N/A	Generator
---	---	-----	-----------

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Is the generator compliant? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are fuels and/or electrical wiring compliant? |

Y	N	N/A	Fire Extinguishers
---	---	-----	--------------------

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Is a "K" Class extinguisher present and have current certification tag? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Do all extinguishers have current certification tags? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are all extinguishers mounted properly? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are all extinguisher brackets free of damage? |

Y	N	N/A	Electrical Systems
---	---	-----	--------------------

- | | | | |
|--------------------------|--------------------------|--------------------------|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are electrical systems compliant? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are approved extension cords present? |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Are approved multi-plug adaptors present? |

Comments: _____

Inspector's Name: _____

Contractor's Name & License # _____

Prosper Fire Department 1500 E. First Street Prosper, Texas 75078
Phone 972-347-2424 • Fax 972-347-3010 • www.prospertx.gov