



PROSPER FIRE RESCUE

FIRE MARSHAL'S OFFICE

PO Box 307

1500 E. First Street

Prosper, Texas 75078

Phone (972) 346-9469 Fax (972) 347-3010 www.prosperfire.com

Top Reasons Fire & Life Safety Inspections Fail

1. Exit lights and emergency lights fail to operate on battery power
 2. Extension cords are used in lieu of permanent power
 3. Misuse of multi-plug adaptor devices
 4. Storage is too close to sprinkler heads or ceilings
 5. Storage too close to electrical panels
 6. Emergency exit doors are locked or obstructed
 7. Combustible materials stored too close to water heaters and/or heating units
 8. Combustible & flammable liquids not stored in proper cabinets
 9. Missing Building address and/or suite address on front & back doors
 10. Fire lane markings not maintained
 11. Sprinkler suppression systems & fire alarm systems past due for annual inspections
 12. Kitchen hood suppression systems and Alternative suppression systems past due for annual inspections
 13. Loose electrical wiring, breakers missing from panels creating gaps, missing electrical box covers
 14. Knox Boxes not maintained with Keys & identification tags (all necessary keys to gain access into the structure & internal spaces, elevator and fire alarm control units) for all Knox Boxes
- 1) [For more information, visit our web page listed below and/or questions contact one of the numbers listed below.](#)

Web page: www.prosperfire.com/fire-department/fire-marshall Email Correspondence: fire.inspections@prosperfire.com

Technical Questions: 972-346-9469

General Questions: 972-347-2424